Wisconsin Department of Safety and Professional Services Division of Industry Services 1400 East Washington Avenue PO Box 7302 Madison, WI. 53707-7302



Phone: 608-266-2112 Web: http://dsps.wi.gov Email: dsps@wisconsin.gov

Electric Pellet Grills FAQ

Q: Are wood pellet grills which are UL Listed and have enclosed electric elements allowed on balconies in multi-family occupancies under NFPA 1?

A: Wood pellet grills would not be allowed as they are fundamentally different from electric grills in that the wood pellets ignite and produce a flame.